

Organisation Details

Type: Central PSU
 Ministry: Ministry of Coal
 Department: Materials Management
 Organisation Name: Bharat Coking Coal Limited
 Office Zone: Bccl Dhanbad

Buyer Details

Name: Vikky Anand
 Designation: Assistant Manager
 Contact No.: 94705-95937-
 Email ID: buyer9.bccl.dhn@gembuyer.in
 GSTIN: 20AAACB7934MFZB
 Address: MM Department, level 3, Commercial Building, Koyla Bhawan, Koyla Nagar, DHANBAD, JHARKHAND-826005, India

Financial Approval Detail

IFD Concurrence: Yes
 Designation of Administrative Approval: Dir (Tech) OP, BCCL.
 Designation of Financial Approval: Dir (Tech) PP, BCCL.

Paying Authority Details

Name: BIKRAM GHOSH
 Designation: HOD Purchase Finance
 Email ID: hodpurfin.bccl@nic.in
 GSTIN: N
 Address: MM Department, level 3, Commercial Building, Koyla Bhawan, Koyla Nagar, DHANBAD, JHARKHAND-826005, India

Seller Details

Company Name: Rishabh Engineering Company
 Contact No.: 09810373494
 Email ID: vinamra@dgsetsindia.com
 Address: 217 Richpalpuri, Opp Hapur Mode, G T Road, Ghaziabad, Ghaziabad, UTTAR PRADESH-201001, -
 MSME verified: Yes
 MSE Social Category: General
 MSE Gender: Male
 GSTIN: 09AAJFR9863P1Z0

Product Details

#	Item Description	Category Name	Model	HSN Code	Ordered Quantity	Unit	Price (Inclusive of all Duties and Taxes in INR)
1	DIESEL GENERATOR	diesel generators- DG Sets	RISHABH TATA RT40	85021200	1	pieces	390,600
2	62.5 KVA DIESEL GENERATOR	diesel generators- DG Sets	RISHABH TATA RT62.5	85021200	1	pieces	504,000
3	62.5 KVA DIESEL GENERATOR	diesel generators- DG Sets	RISHABH TATA RT62.5	85021200	1	pieces	504,000
Total Order Value (in INR)							1,398,600

Consignee Detail

S.No	Consignee	Item	Lot No.	Quantity	Delivery Start After	Delivery To Be Completed By
1	Name: Prabhakar Kumar Designation: - Email ID: prabhakar.k5730@nic.in Contact: 94705-96918- GSTIN: - Address: Depot Officer, Bera Regional Store, Near Dowari colliera, Bastacolla Area, P.O. Dhansar, Dhanbad., DHANBAD, JHARKHAND-828106, India	DIESEL GENERATOR	-	1	03-Aug-2020	17-Sep-2020
		62.5 KVA DIESEL GENERATOR	-	1	03-Aug-2020	17-Sep-2020
	Name: Rohit Kumar					

2	Designation: - Email ID: con1.bccl.jh@gembuyer.in Contact: 62876-95727- GSTIN: - Address: Depot Officer, Central Store, Ekra, BCCL, Post Office- BANSJORA, Dhanbad, Jharkhand-828101., DHANBAD, JHARKHAND-828101, India	62.5 KVA DIESEL GENERATOR	-	1	03-Aug-2020	17-Sep-2020
---	---	------------------------------	---	---	-------------	-------------

Product Specification for DIESEL GENERATOR

Specification	Sub-Spec	Value
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (KVA)	40
	No of Phase	Three Phase
ENGINE	Make of Engine	TATA MOTORS LTD
	Model Number of Engine	497TC
	Capacity of Engine (cc)	3800
	Engine Power (kWm)	47
	ISI Marking to IS :10001 for engine	No
	BIS license No, if applicable	NA
	Type of Engine cooling	Liquid Cooled
	Type of governer	Mechanical
	Class of governer	A1
	Number of cylinders (nos)	4
	No of Strokes (nos)	4
	Rated RPM of Engine (RPM)	1500
	Overload capacity for one hour for every 11 hours continuous running at full load (%)	10
	Specific Fuel Consumption (gm/kWh)	228
Starting voltage (volt)	12	
ALTERNATOR	AC GENERATOR(ALTERNATOR) Make	STAMFORD
	AC GENERATOR(ALTERNATOR) model Number	S1L2-K1
	Rating of AC Generator (KVA)	40
	Power Factor of AC generator	0.8
	Efficiency at rated Power factor at 75% of full Load	90.1
	Compliance of Alternator to IS:13364(part-1)	Yes
	Type of alternator	Brushless
	Voltage Regulation Grade	VG 3
	Alternator IP Rating	IP 23
	Class of Insulation	H
CONTROL PANEL	Control Panel	AMF
	IP Rating of Control Panel	IP 55
ACOUSTIC ENCLOSURE	Sheet Thickness	1.6
	Thickness of Foam	40
	Density of Foam for sound insulation	32
	Noise level at 1 meter (dB)	75
		Low Maintenance free to IS: 14257 for

BATTERY	Battery Type & Specification	high cranking performance
	Battery capacity (Ah)	90
	No of batteries	1
TEST REPORTS	Availability of Type test report for Engine from Central govt/NABL/ILAC accredited laboratory	Yes
	Test Report number and date(Engine)	ARAI/MoEF/DGTA/TML-F24/2014-03 17 JUNE 2014
	Name and address of laboratory(Engine)	PUNE
	Availability of Type test report for Alternator from Central government/NABL/ILAC accredited laboratory	Yes
	Test Report number and date(Alternator)	G17H316471 03.08.17
	Name and address of laboratory(Alternator)	CGT INDIA LTD AHMEDNAGAR
	DG set meet requirements of Environmental(Protection) Rules 1986, in respect of noise and emission norms, as described in STC	Yes
WARRANTY / INSTALLATION & COMMISSIONING	Warranty	2
	Installation & Commissioning	With Installation
	Agreed to STC of the Product	Yes

Product Specification for 62.5 KVA DIESEL GENERATOR

Specification	Sub-Spec	Value
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (KVA)	62.5
	No of Phase	Three Phase
ENGINE	Make of Engine	TATA MOTORS LTD
	Model Number of Engine	497TC
	Capacity of Engine (cc)	3800
	Engine Power (kWm)	67
	ISI Marking to IS :10001 for engine	No
	BIS license No, if applicable	NA
	Type of Engine cooling	Liquid Cooled
	Type of governer	Mechanical
	Class of governer	A1
	Number of cylinders (nos)	4
	No of Strokes (nos)	4
	Rated RPM of Engine (RPM)	1500
	Overload capacity for one hour for every 11 hours continuous running at full load (%)	10
	Specific Fuel Consumption (gm/kWh)	228
	Starting voltage (volt)	12
ALTERNATOR	AC GENERATOR(ALTERNATOR) Make	STAMFORD CROMPTON
	AC GENERATOR(ALTERNATOR) model Number	S1L2-Y1 G1R200SC
	Rating of AC Generator (KVA)	62.5
	Power Factor of AC generator	0.8
	Efficiency at rated Power factor at 75% of full Load	91.8
	Compliance of Alternator to IS:13364(part-1)	Yes

	Type of alternator	Brushless
	Voltage Regulation Grade	VG 3
	Alternator IP Rating	IP 23
	Class of Insulation	H
CONTROL PANEL	Control Panel	AMF
	IP Rating of Control Panel	IP 53
ACOUSTIC ENCLOSURE	Sheet Thickness	1.6
	Thickness of Foam	50
	Density of Foam for sound insulation	38
	Noise level at 1 meter (dB)	75
BATTERY	Battery Type & Specification	Low Maintenance free to IS: 14257 for high cranking performance
	Battery capacity (Ah)	90
	No of batteries	1
TEST REPORTS	Availability of Type test report for Engine from Central govt/NABL/ILAC accredited laboratory	Yes
	Test Report number and date(Engine)	ARAI/MoEF/2014-03
	Name and address of laboratory(Engine)	ARAI PUNE
	Availability of Type test report for Alternator from Central government/NABL/ILAC accredited laboratory	Yes
	Test Report number and date(Alternator)	G12E182215, QEF23
	Name and address of laboratory(Alternator)	CEIL DGS&D PUNE
	DG set meet requirements of Environmental(Protection) Rules 1986, in respect of noise and emission norms, as described in STC	Yes
WARRANTY / INSTALLATION & COMMISSIONING	Warranty	2
	Installation & Commissioning	With Installation
	Agreed to STC of the Product	Yes

Product Specification for 62.5 KVA DIESEL GENERATOR

Specification	Sub-Spec	Value
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (KVA)	62.5
	No of Phase	Three Phase
ENGINE	Make of Engine	TATA MOTORS LTD
	Model Number of Engine	497TC
	Capacity of Engine (cc)	3800
	Engine Power (kWm)	67
	ISI Marking to IS :10001 for engine	No
	BIS license No, if applicable	NA
	Type of Engine cooling	Liquid Cooled
	Type of governer	Mechanical
	Class of governer	A1
	Number of cylinders (nos)	4
	No of Strokes (nos)	4

	Rated RPM of Engine (RPM)	1500
	Overload capacity for one hour for every 11 hours continuous running at full load (%)	10
	Specific Fuel Consumption (gm/kWh)	228
	Starting voltage (volt)	12
ALTERNATOR	AC GENERATOR(ALTERNATOR) Make	STAMFORD CROMPTON
	AC GENERATOR(ALTERNATOR) model Number	S1L2-Y1 G1R200SC
	Rating of AC Generator (KVA)	62.5
	Power Factor of AC generator	0.8
	Efficiency at rated Power factor at 75% of full Load	91.8
	Compliance of Alternator to IS:13364(part-1)	Yes
	Type of alternator	Brushless
	Voltage Regulation Grade	VG 3
	Alternator IP Rating	IP 23
	Class of Insulation	H
CONTROL PANEL	Control Panel	AMF
	IP Rating of Control Panel	IP 53
ACOUSTIC ENCLOSURE	Sheet Thickness	1.6
	Thickness of Foam	50
	Density of Foam for sound insulation	38
	Noise level at 1 meter (dB)	75
BATTERY	Battery Type & Specification	Low Maintenance free to IS: 14257 for high cranking performance
	Battery capacity (Ah)	90
	No of batteries	1
TEST REPORTS	Availability of Type test report for Engine from Central govt/NABL/ILAC accredited laboratory	Yes
	Test Report number and date(Engine)	ARAI/MoEF/2014-03
	Name and address of laboratory(Engine)	ARAI PUNE
	Availability of Type test report for Alternator from Central government/NABL/ILAC accredited laboratory	Yes
	Test Report number and date(Alternator)	G12E182215, QEF23
	Name and address of laboratory(Alternator)	CEIL DGS&D PUNE
	DG set meet requirements of Environmental(Protection) Rules 1986, in respect of noise and emission norms, as described in STC	Yes
WARRANTY / INSTALLATION & COMMISSIONING	Warranty	2
	Installation & Commissioning	With Installation
	Agreed to STC of the Product	Yes

Terms and Conditions

1. Special terms and conditions

1.1 In addition to General Terms and Conditions of GeM, Special T&C shall be applicable for Diesel Generating Set/DG Set. [click here](#) to view the Special terms and conditions.

2. General Terms and Conditions

2.1 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) as available on the GeM portal (unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

2.2 Terms of delivery: Free Delivery at Site including loading/unloading. In respect of items requiring installation and / or commissioning and other services in the scope of supply (as indicated in respective product category specification / STC / ATC), and the cost of the same is also included in the Contract price.

2.3 Delivery period: The Delivery Period/Time shall be essence of the Contract and delivery must be completed not later than such date(s). Any modification thereto shall be mutually agreed and incorporated in the Contract as per the provisions of the GTC.

2.4 Performance Security: If the Seller fails or neglects to observe or perform any of his obligations under the contract it shall be lawful for the Buyer to forfeit either in whole or in part, the Performance Security furnished by the Seller.

2.5 Taxes and Duties: Contract Prices are all inclusive i.e. including all taxes, duties, local levies / transportation / loading-unloading charges etc. Break up of GST shall be indicated by the Seller while raising invoice / bill on GeM. While submitting the bill / invoice Seller shall undertake that the Goods and Services Tax (GST) charged on this bill is not more than what is payable under the provision on the relevant Act or the Rules made there under and that the Goods on which GST has been charged have not been exempted under the GST Act or the Rules made there under and the charges on account of GST on these goods are correct under the provision of that Act or the rules made there under.

2.6 Octroi Duty and / or other local taxes: Contract Prices are all inclusive hence no reimbursement over and above the contract price(s) shall be allowed to seller towards payment of local taxes (such as levy of town duty, Octroi Duty, Terminal Tax and other levies of local bodies etc).

2.7 Limitation of Liability: The provisions of limitation of liability between Buyer and Seller as given in the GTC shall be applicable here.

2.8 Resolution of disputes: The provisions of DISPUTE RESOLUTION BETWEEN BUYER AND SELLER as given in the GTC shall be applicable here.

2.9 Liquidated Damages: If the Seller fails to deliver any or all of the Goods/Services within the original/re-fixed delivery period(s) specified in the contract, the Buyer will be entitled to deduct/recover the Liquidated Damages for the delay, unless covered under Force Majeure conditions aforesaid, @ 0.5% per week or part of the week of delayed period as pre-estimated damages not exceeding 10% of the contract value without any controversy/dispute of any sort whatsoever. In case, Service Level Agreement (SLA) is applicable the same shall be applicable for the Contract.

2.10 Financial Certificate:

2.10.1 The expenditure involved for this purpose has received the Sanction of the competent financial authority.

2.10.2 The funds are available under the proper head in the sanction budget allotment for the concern financial year.

2.10.3 I have been fully authorized by the department to sign the supply order or incur the liability of the Goods being ordered.

2.11 The bidder should submit a self declaration to the effect in bidder's official letter head that their agency have not been black listed by any Agency whatsoever till date.

3. Additional Terms and conditions

3.1 Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

3.2 Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for percentage of 25% of total value.

3.3 Preference to Make In India products: Preference shall be given to local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a local supplier, should be as per relevant notification / order issued by the nodal ministry as available on the website of Department of Promotion of Industries and Internal Trade (DPIIT). If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 29.5.2019.

3.4 Timely Servicing / rectification of defects during warranty period: After having been notified of the defects / service requirement during warranty period, Seller has to complete the required Service / Rectification within 15 days time limit. If the Seller fails to complete service / rectification with defined time limit, a penalty of 0.5% of Unit Price of the product shall be charged as penalty for each week of delay from the seller. Seller can deposit the penalty with the Buyer directly else the Buyer shall have a right to recover all such penalty amount from the Performance Security (PBG).Cumulative Penalty cannot exceed more than 10% of the total contract value after which the Buyer shall have the right to get the service / rectification done from alternate sources at the risk and cost of the Seller besides forfeiture of PBG. Seller shall be liable to re-imburse the cost of such service / rectification to the Buyer.

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.