

Contract | अनुबंध



Contract No | अनुबंध क्रमांक: GEMC-511687766974000

Generated Date | अनुबंध तिथि: 22-Aug-2023

Bid/RA/PBP No. | बोली/आरए/पीबीपी संख्या: [GEM/2023/B/3355603](#)

Organisation Details संगठन विवरण	Buyer Details खरीदार विवरण
Type प्ररूप: Central PSU Ministry मंत्रालय: Ministry of Coal Department विभाग: Materials Management Organisation Name संगठन का नाम: Bharat Coking Coal Limited Office Zone कार्यालय क्षेत्र: Bccl Dhanbad	Designation पद: Manager Contact No. संपर्क नंबर: 94705-95938 Email ID ईमेल आईडी: mrunal.mehta@nic.in GSTIN जीएसटीआईएन: 20AAACB7934MFZB Address पता: MM Department, level 3, Commercial Building, Koyla Bhawan, Koyla Nagar, DHANBAD, JHARKHAND-826005, India

Financial Approval Detail वित्तीय स्वीकृति विवरण	Paying Authority Details भुगतान प्राधिकरण विवरण
IFD Concurrence आईएफडी सहमति: No Designation of Administrative Approval प्रशासनिक अनुमोदन का पदनाम: DT(PP) Designation of Financial Approval वित्तीय अनुमोदन का पदनाम: GM(MM)	Role: PAO Payment Mode भुगतान का तरीका: Offline Designation पद: Senior Manager Email ID ईमेल आईडी: pay8.bccl.dhn@gembuyer.in GSTIN जीएसटीआईएन: 20AAACB7934MFZB Address पता: MM Department, level 3, Commercial Building, Koyla Bhawan, Koyla Nagar, DHANBAD, JHARKHAND-826005, India

Seller Details विक्रेता विवरण	
GeM Seller ID जेम विक्रेता आईडी: 8064180000092608 Company Name कंपनी का नाम: ALLIANCE INFOTECH Contact No. संपर्क नंबर: 09905156421 Email ID ईमेल आईडी: raju23202@yahoo.co.in Address पता: 206,HERITAGE COMPLEX,NEAR RMCH,BARIATU, RANCHI, JHARKHAND-834009, - MSME verified एमएसएमई सत्यापित: No MSME Registration number एमएसएमई पंजीकरण संख्या: UDYAM-JH-20-0010841 MSE Social Category एमएसएमई सामाजिक श्रेणी: General MSE Gender एमएसएमई लिंग श्रेणी: Male GSTIN जीएसटीआईएन: 20AANFA0219Q2ZI	

*GST / Tax invoice to be raised in the name of | जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा - Consignee

Delivery Instructions | वितरण निर्देश: NA

Product Details उत्पाद विवरण						
#	Item Description आइटम विवरण	Ordered Quantity आइटम विवरण	Unit इकाई	Unit Price (INR) इकाई मूल्य (INR)	Tax Bifurcation (INR) कर विभाजन (INR)	Price (Inclusive of all Duties and Taxes in INR) मूल्य (INR में सभी शुल्क और कर सहित)
1	Product Name उत्पाद का नाम: A V O Online UPS of Rating 3.0 KVA With Battery Of Backup Time 120 Minutes Brand ब्रांड: A V O Brand Type ब्रांड प्रकार: Registered Brand Catalogue Status कैटलॉग की स्थिति: OEM verified catalogue Selling As कैसे बेचा जा रहा है: OEM verified Reseller Category Name & Quadrant श्रेणी का नाम और चतुर्थांश: Online UPS (V2) (Q2) Model मॉडल: HP303 HSN Code एचएसएन कोड: HSN not specified by seller	2	pieces	89,730	NA	179,460
Total Order Value कुल ऑर्डर मूल्य (in INR)						179,460

Consignee Detail परेषिती विवरण						
S.No क्र.सं.	Consignee परेषिती	Item वस्तु	Lot No. लॉट नंबर	Quantity मात्रा	Delivery Start After दिनांक के बाद डिलीवरी शुरू करना है	Delivery To Be Completed By वितरण पूरा कब तक करना है

1	Designation पद : - Email ID ईमेल आईडी : con1.bccl.jh@gembuyer.in Contact संपर्क : 62876-95727- GSTIN जीएसटीआईएन : 20AAACB7934MFZB Address पता : Depot Officer, Central Store, Ekra, BCCL, Post Office- BANSJORA, Dhanbad, Jharkhand-828101., DHANBAD, JHARKHAND-828101, India	A V O Online UPS of Rating 3.0 KVA With Battery Of Backup Time 120 Minutes	-	2	22-Aug-2023	20-Nov-2023
---	---	---	---	---	-------------	-------------

Product Specification for A V O Online UPS of Rating 3.0 KVA With Battery Of Backup Time 120 Minutes

Specification विनिर्देश	Sub-Spec उप-विनिर्देश	Value मूल्य
Generic	Rating in KVA	3.0 KVA
	Switching Technology	IGBT-PWM
	Input Voltage	AC Single phase 160V - 260V 50Hz
	Output Voltage	AC Single phase 230V +/-1% 50 Hz
	Warranty for UPS (Years)	3
Battery/Backup Bank	Battery/Backup Bank Provided with Online UPS (Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021)	With Battery
	Type of Battery (hint: NA in case Battery not provided)	SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest
	Backup time (Minutes) (hint: NA in case battery not provided)	120 Minutes
	Battery Make	EXIDE
	Battery Model Number	EP 65AH-12
	Battery capacity (Ah)	65
	Weight of the Battery (kg)	21
	Number of Batteries	96
	Minimum Guaranteed VAH	1600 X Per KVA X Per hour of backup time
	Warranty for battery (Years) by Battery Manufacturer/Brand hint: NA in case battery not provided	3
Accessories with Battery	NA	
Installation and Commissioning or Service	Installation and Commissioning (Covered in the Scope of Supply)	Provided
	After sales service (Turn Around Time)	Within 48 hours, Within 7 days
	Preventive Maintenance (Hint: Mention Timeline if provided, NA if not provided)	NA
	Other Services provided	PAN India service support on 24 x 7 basis, AMC support available warranty
Performance / Functional	Inbuilt isolation transformer	With
	Overall Efficiency (%)	>/=80% & <90% with Inbuilt isolation transformer
	Power Factor Load Supported	0.8 or better
	Overload limit	50% Overload for minimum 3 seconds
	Total Harmonic Distortion(THD) (%)	3% Maximum @ 100% Linear Load
	Other Functional Features	Crest factor on full non-linear load is not less than 3:1, Noise level (1 meter distance from UPS) should be less than 70dB
Accessories	Accessories	Rack for Batteries
Salient Features	Protection	Protection for under voltage at battery terminal, Protection of Over voltage, Short Circuit & over load at UPS output terminal, Over temperature protection
	Metering	Input Voltage, Output Voltage, Input Current, Output Current, Input Power, Output Power
	Alarms and Indications	Indicator for Mains presence
	Additional Features	Pure Sinewave AC Output
Design / Construction	Type of Design / Construction	Floor Standing
	Form factor of UPS	NA (for Floor Standing)
	Enclosure (mm)	1.0 mm Minimum Thickness of M.S. Sheet duly powder coated
	Degree of Protection	IP20

	DC Bus Voltage (In Volts)	96
	Other Constructional Features	Mains ON/OFF MCB,Battery ON/OFF MCB
Operating Conditions	Minimum Operating Temperature	-5 degree Celsius
	Maximum Operating Temperature	45 degree Celsius
	Relative Humidity Non Condensing at 40 deg C	85 percent
Buyer Specific Requirement	Environmental Test Report Requirements	NA
	Battery Test Report	NA
	Intended Applications	Medical Equipment
	Other Requirements	ROHS compliance,KW rating shall be 0.8 time of KVA rating
Reports And Certification	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	OEM
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes (For UPS rating upto 10KVA)

ePBG Detail | ईपीबीजी विवरण

Advisory Bank | सलाहकार बैंक :

NA

ePBG Percentage(%) | ईपीबीजी प्रतिशत (%) :

NA

Terms and Conditions | नियम और शर्तें

1. Special terms and conditions- Version:1 effective from 06-07-2022

1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS (Version 2.0) with reference to Installation and Commissioning.

Seller's Responsibility: Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

Buyer's Responsibility: Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commissioning.

Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.

2. General Terms and Conditions-

2.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.

2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

3. Buyer Added Bid Specific Terms and Conditions-

3.1 Scope of Supply:

Scope of supply (Bid price to include all cost components) : Supply Installation Testing Commissioning of Goods and Training of operators and providing Statutory Clearances required (if any)

3.2 Generic:

Manufacturer Authorization:Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।