

	BHARAT COKING COAL LIMITED (A Subsidiary of Coal India Limited) Office of the General Manager(MM) Materials Management Department Commercial Block L-III , Koyla Bhawan : Koyla Nagar Dhanbad : 826005(Fax No- 0326-2230183) Web site: www.bccl.gov.in
SUPPLY /PURCHASE ORDER	Under Jurisdiction Of Dhanbad Court And Jharkhand High Court Only.

Ref #: BCCL /Pur/111027/VCB CCB/11-12/91/124/

Dated: 03-10-2012

To

REG. POST

M/s ELECTROTEKNIKA

(FAX-033-24427888)

9,Prantik Pally,KMC-128

VENDER CODE: 1/12/M/T/011

Bosepukur,

Kolkata-700042

Dear Sirs,

Sub: Our Tender No. PUR/111027/ VCB CCB/11-12/91,Opened on 24.10.2011

Ref: Your Offer #: Your offer No. 1147/ET/SB, Dt: 17-10-2011and subsequent

Correspondence on the above subject.

With reference to the above we are pleased to place our order on you for the supply of "**VCB to Control Capacitor Bank**" as per the rates and terms and conditions detailed hereunder:

1.Scope of supply:

SN	Description	Tender QTY (No's)	Unit Rate /No.	Extended Value
1	VCB to Control Capacitor Bank	4	237500.00	950000.00
	E.D. & Cess @12.36%			117420.00
	Sub-Total(Rs.)			10,67,420.00
	CST @ 2%			21348.40
	Packing & forwarding @1000/No.			4000.00
	Freight @ Rs. 7000.00/No.			28000.00
	Total Landed Value			1120768.40
	CMPDIL Inspection Charge @ 0.8% of F.O.R. Destination value(Rs.)			8966.15
	Service Tax on CMPDIL Inspection charge @12.36 % (Rs.)			1108.22
	GRAND TOTAL LANDED VALUE (Rs.)			11,30,842.77
	Round off (Rs.)			11,30,843.00

(Rupees Eleven Lakhs Thirty Thousand Eight hundred Forty Three only)**(Detailed Technical specification will be as per Annexure "A" at pages 6-10)**

2. TOTAL ORDER VALUE : The total procurement value of 04 No of VCB to Control capacitor Bank comes out to **Rs 11,30,843.00 (Rs. Eleven lakhs Thirty Thousand Eight**

Hundred Forty Three Only) on F.O.R. Destination basis inclusive of all taxes & duties and inspection charges with service tax payable to CMPDIL.

3. PRICE- Firm and FOR Destination.

4. E.D. & Cess – Payable Extra as applicable within delivery schedule at actual on production of documentary evidence, Present rate of E.D. & Cess is 12.36 % .

5. CST: Payable Extra as applicable within delivery schedule at actual on documentary evidence, Present rate of CST is @ 2 % .

6. PAYMENT TERM:- 100% within 21 days of receipt and acceptance of the materials by the consignee or from the date of receipt of bill whichever is later by the consignee.

7. PACKING & FORWARDING CHARGE: As indicated in above .

8. FREIGHT :- Freight should be paid at actual against documentary evidence subject to maximum as indicated above.

9. Transit INSURANCE CHARGES : Nil.

10. MODE OF DISPATCH : By Road on F.O.R. Destination ,Freight paid basis

NOTE : You will ensure safe & sound delivery of stores at consignee's end .

11. ROAD PERMIT : Road permit, if required masy be obtained directly from the consignee under intimation to this office.

12 .DELIVERY PERIOD : Within (06) Six months from the date of receipt of Purchase Order However, keeping in view of our urgency, earliest delivery will be appreciated. Delivery period shall be reckoned from 10th day of placement of order. Any increase in the rate of taxes & duties beyond delivery period will be on your account.

13. Consignee:	14. Paying Authority
The Depot Officer, Central Stores, Ekra, B.C.C.L.	The General Manager (F)MM , Purchase Finance, Koyla Bhawan, B.C.C.L. , Dhanbad

15.SUBMISSION OF BILL: 100% value of bill duly stamped, signed & pre-receipted in five copies ,as per terms of the order should be submitted for payment to the paying authority through consignee. Bill should be submitted along with challan, Consignment note (if required), packing list if any, Guarantee/Warranty certificate, fitment / Test certificate if required , proof of payment of freight charges if freight is claimed, documentary evidence of Excise duty payment if claimed, Price Certificate, Copy of Inspection Note of CMPDIL (If required) and other documents as per order.

(Note – All documents to be submitted shall be duly authenticated)

(No payment will be made without submission of performance Bank Guarantee & security deposit).

THE DESIRED INFORMATION FOR RAISING VAT/CENVAT INVOICE		
	SUPPLIER	CONSIGNEE
Name & Address Of Area:		Ekra Central Store, Block – II Area, BCCL, Nawagarh, Dhanbad, Jharkhand – 828306
Tin No.:		20821500736
JST No.:		KT – 651 (R)
CST No:		KT – 254 (C)
Circle / Sub		Katras Circle Katras
Service Tax Regd. No:		AAACB7934MST 009
Central Excise Duty Regd. No:		AAACB7934MEM 007
Range (Code):		Dhanbad - Code - 02
Division (Code		Dhanbad - Code - 02
Commissionerate (Code):		Ranchi - Code – 87

PARTICULARS OF BANK ACCOUNT:	ELECTROTEKNICA 9, Prantik Pally, KMC-128,Bosepukur,Kolkata-700042
Name of the Bank.	State Bank of India
Name of the Branch with complete address.	54,Ekdalia Road,, Kolkata-700019
Party's Account Style.	ELECTROTEKNICA
Party's nature of Account.	Cash Credit
Party's Account Number.	30662086641

16. GUARANTEE /WARRANTY : The supplier shall guarantee for the satisfactory performance of the complete equipment/ stores for a period of 12 months from the date of commissioning or 18 months from the date of dispatch, whichever is earlier, against any manufacturing defects / workmanship / inferior quality. Any defect observed on this account shall be attended immediately and replace the materials within 30 days free of cost.

17. PRICE CERTIFICATE: You should submit a certificate along with bill as stated below:

"The rates of the stores under this contract are the lowest at which we are selling to any other Customer / Govt. Deptt./ Subsidiaries of CIL/ Other PSUs . If the materials are sold at any lower rate than that mentioned in this contract to any other agency, the same will automatically be applied to this contract from that date".

18. SECURITY DEPOSIT: Waived as being registered with NSIC .

19. INSPECTION – Pre-dispatch inspection of each consignment shall be carried out by M/s. Central Mine Planning & Design Institute Ltd(CMPDIL), Ranchi/their Regional Office as per the terms and conditions indicated hereunder:

Pre-dispatch inspection shall be carried out by M/s.CMPDIL(the above firm) as per their methodology. The third Party Inspection shall include examination of raw material, test certificate verification, continuous monitoring of quality assurance by manufacturer which will include regular and surprise visits. In brief, the scope and condition of inspection by M/s.CMPDIL will be as follows :

Checking and approval of test procedures/quality assurance plans. Verification of records and documents of your works. Verification of documents and test certificate of bought out items and cross checks.

You shall provide facilities for carrying out all necessary tests as required in the specification at your works else these will be carried out at an independent test house at your cost. Final testing and checking of materials as per specifications.

M/s.CMPDIL will have full and free access to the premises of manufacturer during the process of manufacturing and during inspection activities.

Inspection fee @ 0.80% of total F.O.R. Destination price with service Tax of 12.36%%, is to be paid to M/s.CMPDIL alongwith inspection call letter payable by DD which will be reimbursed subsequently by BCCL together with consignment billing.

Minimum 7 calendar days notice shall be given by you to M/s.CMPDIL for arranging inspection within valid delivery period as per contract. The ultimate responsibility for supply of correct materials as per requirement of relevant specification lies solely with you inspite of clearance/acceptance by inspection authority i.e. M/s.CMPDIL. The manufacturer will be required to replace the material free of cost if found defective/unserviceable/not according to relevant specifications. The charges for third party inspection and the cost of materials that would be required for destructive tests, if any, shall be reimbursed by BCCL together with the consignment billing. Such cost shall be reimbursed only if it is duly certified by M/s.CMPDIL.

Please send inspection call to M/s.CMPDIL, Ranchi/ their Regional Office as indicated above Final inspection shall be arranged by the consignee after receipt of the material at our

destination. The purchaser shall, at its discretion, have the right to test the ordered material in a Government Test House or in a test house nominated by the purchaser. In case of failure of the material after testing the cost of tests as well as of the material shall have to be borne by the supplier. Final inspection shall be arranged by the consignee after receipt of the material at our destination.

The purchaser shall, at its discretion, have the right to test the ordered material in a Government Test House or in a test house nominated by the purchaser. In case of failure of the material after testing the cost of tests as well as of the material shall have to be borne by the supplier.

20. PERFORMANCE BANK GUARANTEE – PBG on schedule/Nationalized Bank in India valid for three months beyond the expiry of Guarantee/Warranty period for 10 % value of the order (order value means FOR destination price including taxes, duties, transportation & insurance charges & other charges if any) shall have to be submitted to MM Division, BCCL, Koyla Bhawan on or before commencement of supply. PBG may be submitted either for the entire order quantity at a time or each equipment wise/lot wise.

21. PENALTY FOR FAILURE TO SUPPLY IN TIME

The bidders will confirm their acceptance of the following **Liquidated Damage Clause:**

In the event of failure to deliver the equipment/stores within the stipulated date/period to effect supply in accordance with the terms and conditions and the specifications mentioned in the supply order and in the event of breach of any of the terms and conditions mentioned in the supply order, Bharat Coking Coal Ltd., shall be entitled at its option either to enforce the following:

- a) To recover from the successful bidder as agreed liquidated damages, a sum of 0.5%(Half Percent) of the price of any stores which the successful tenderer has not been able to supply as aforesaid for each week or part of a week during which the delivery of such stores may be in arrears limited to **10% (Ten Percent)** and where felt necessary by BCCL it may be increased up to 15 %.
- b) To cancel the supply order or a portion thereof, and if so desired to purchase the stores at the risk and expenses of the defaulting supplier and also/or
- c) To purchase elsewhere after notice to the successful tenderer on the account and at the risk of the defaulting supplier, the equipment/stores not supplied or others of similar description without canceling the supply order in respect of the consignment not yet due for supply/or
- d) To extend the period of delivery with or without liquidated damages as may be considered fit and proper. The liquidated damages if imposed, shall not be more than the agreed liquidated damages referred to in CLAUSE 14 (a) above except in case of force majeure condition.
- e) Whenever under this contract any sum of money is recoverable from and payable by the supplier, Bharat Coking Coal Ltd., shall be entitled to recover such sum by appropriating in part or in whole by deducting any sum or which at any time thereafter may become due to the successful tenderer in this or any other contract, should this sum be not sufficient to recover the full amount recoverable. The successful tenderer shall pay to Bharat Coking Coal Ltd., the balance amount on demand of the remaining balance. The supplier shall not be entitled for any gain on any such purchase.
- f) To forfeit the security deposit fully or in part.

22. PRICE FALL CLAUSE :

i) The price charged for the Stores / Equipment supplied against the order, if placed, shall in no event exceed the lowest price at which the bidder shall sell or offer to sell the Stores / Equipment of identical description to its any other customer during the pendency of the Contract / Supply Order. If the successful tenderer at any time during the pendency of the Contract / Supply Order sells or offers to sell such stores to any customer, at a price lower than the price stipulated in the Contract / Supply Order placed by BCCL, the successful tenderer shall forthwith notify to BCCL such reduction in sale price of stores / equipment supplied after such reduction coming into force shall stand correspondingly reduced.

All other terms & conditions along with Technical Specifications and Scope of supply will strictly be as per our NIT and company's norms.

ALL DISPUTES ARE SUBJECT TO DHANBAD COURT AND JHARKHAND HIGH COURT JURISDICTION ONLY.

This contract is concluded with the issuance of this order. Two copies of the order is being sent to you. You are advised to acknowledge the receipt and acceptance of the order by returning one copy duly signed and stamped to this office positively within 15 days, failing which this order shall be deemed to have been accepted by you for execution.

Indent # And Date	Budget Certification & FC No And Date
BCCL/CGM(E&M)/F-Central Indent (Elect)/2010-11/030 Dated:21.01.2011	BCCL/C&B/CAP/12-13/P&M/HQ/120/94/244 e-BC Dt:- 22-09-2012 For Rs. 11,30,843.00 e-FC no 90 dt:- 26-09-2012 (HQ P&P) For Rs. 11,30,843.00

- 1. CGM (E&M), BCCL, Koyla Bhawan.
- 2. GM (Finance), MM, BCCL, Koyla Bhawan.
- 3. Depot Officer, Central Store, Ekra, BCCL.
- 4. CGM (E&M), CMPDIL, Gondwana Place, Kanke Road, Ranchi.
- 5. Technical Cell, MMD, Koyla Bhawan
- 6. Justice Ashok Kumar Chakraborty (Retd), BB-69, Sector I Salt Lake, Kolkata – 700 064
- 7. Special Cell, CMPDIL, Gondwana Place, Kanke Road, Ranchi
- 8. CGM (MM)/GM (MM): SECL, CCL, WCL, NCL, MCL, ECL, CMPDIL

Yours faithfully,
For & on behalf of Bharat Coking Coal Ltd.

(Niraj Kumar)
Manager(Excvn)MM

(A. K. Choudhary)
CM (MM)

Annexure-'A''

SPECIFICATION FOR 11KV SWITCHGEAR

For capacitor control panel

The VCB shall be indoor type with copper bus bar of suitable rating and suitable for 3 phase 50 HZ ac supply . The VCB should be of free standing floor mounted , dust and vermin proof sheet steel clad cubical . Sheet steel should be of suitable thickness and shall be degreased , pickles phosphated , putti finished , pretreated with two coats of anti corrosive primer and finally treated with two coats of dark gray enamel paint . The panel unit shall be modular type so that the requisite number of panel units can be installed side by side and bolted together to form a compact panel . The indicating lamps on the panel board should be arranged on single diagram of 12 mm thick in the front portion of the switch board..

1)The panel unit should confirm to ISS : 13118 (amended up to date) and the following technical parameters contain

- 1. Nominal system voltage : 11 KV
- 2. Highest system voltage : 12 KV
- 3. No. of phases : 3
- 4. Frequency : 50 Hz.
- 5. Neutral earthing : Effectively earthed
- 6. Application : Indoor
- 7. Type : VCB
- 8. Rating : 200Ampere
- 9. Symmetrical breaking capacity : 350 MVA
- 10. Making capacity : 2.55 times breaking capacity
- 11. Power frequency with stand voltage for 1 minute : 28 KV
- 12. Ambient temperature : 50° C

2) Each panel shall be self standing, floor mounted and metal clad. The enclosure should be dust proof & vermin proof. The breaker unit should be draw out type. Each panel should be of sheet steel fabrication of suitable gauge.

Panel unit should be complete with

- i) Vertical/horizontal isolation and horizontal draw out type VCB of rated capacity.
- ii) Air insulated bus chamber.
- iii) PT & CT .
- v) Operating mechanism – spring assisted mechanism.
- vi) Provision for manual charging.
- vii) Slow motion lever

viii) Safety interlocks

ix) Wiring with single core stranded copper PVC wiring. Terminal ends should be numbered as per circuit diagram numbers.

x) Frame earthing terminals – 2 nos.

xi) Cable entry box of suitable size – 2 nos. of cable entry box one fitted at the rear and other in the side of panel each fitted with brass gland suitable for PVCDWA cable. There should be provision for fixing the cable entry box on separate removable plate

3) The bus bar should be made of copper, sleeved and supported on non hygroscopic insulation to withstand mechanical stresses in the event of short circuit. Automatic operated safety shutters to be provided.

4) Tripping arrangement shall be through shunt trip coils

5) The VCB unit shall be provided with the following protections –

a) Triple pole, IDMT relay, 50%-200% setting with instantaneous element having 400% -1600% setting for over current 2 nos., and for earth fault 1 no. with a setting range of 05%-40% instantaneous element 100%-400%. CDG61 of ALSTOM or its equivalent.

b) Shall have sensitive earth leakage protection with CBCT with test and reset provision in the front door. The CBCT shall be able to accommodate the cable of suitable rating. Tripping range of ELR should be adjustable between 0A-5A.

c) PROTECTION -

a) Auto re-close test duty – To be provided for avoiding undesirable tripping on transient fault by suitable auto closure relay.

b) Time delay relay – To be provided with minimum setting time of five minutes before re closure of breaker after each tripping .

c) Over voltage relay – To be provided for over voltage protection with IDMT type O/V relay having setting in 7 equal steps of tripping of 10% for tripping whenever system voltage exceeds 110% of capacitor rated voltage or maximum capacitor voltage.

d) No voltage/Under voltage protection – On failure of power supply capacitor bank should trip and not recharge till discharge to safe value of 50 V or less . Instantaneous type U/V relay with low voltage setting with a timer to be provided to prevent re switching of the breaker for 5 minutes after tripping (time to discharge the capacitor to safe limit)

(6) Shall have provision of manually charged spring, remote or local closing arrangement.

7) The VCB unit shall have its instrument mounted in the front access door.

Identification ferrules shall be fitted to all wire terminals to facilitate checking / trouble shooting. Indicating lamps for ON (Red), OFF (Green), Trip (Amber), Mechanical ON & OFF indicators, Test and reset arrangement for earth leakage relay (CBCT operated) are to be provided.

8) 144 mm² flush mounting ammeter scaled to 1.5 line current. Transformer ratio with selector switch.

9) 144 mm² flush mounting voltmeter suitably scaled with selector switch

10) Local and remote selector switch.

- 11) Pistol grip control switch for closing, tripping and neutral position.
- 12) ON/OFF/TRIP indication lamps to be suitably placed in the schematic diagram.
- 13) C.T. ratio – Dual ratio 200 – 100/5 Epoxy moulded current transformer to be provided for protection & metering with adequate burden & class of accuracy.
- 14) Cast epoxy resin insulated potential transformer with HRC fuse should be provided on with draw able truck. Adequate VA for actuation of protective and metering devices . 11 KV primary/110V secondary.
- 15) Testing and test certificates :

The supplier shall furnish a copy of test certificate from approved test house (CPRI) --Minimum breaking capacity(MVA)

Minimum breaking current (Symmetrical) and other tests as per relevant IS specification

Note : The test report should be of similar/higher rating breakers of within the 5 year period.
- 16) Deviation – In case the tenderer is unable to comply with any of the requirement of this standard, the same must be specifically spelt out while quoting against tender enquiry and where not to mention the tenderer shall be fully responsible to meet all the condition of specification. Similarly any deviation from the standard laid down hearing with a view to improve the performance of the equipment shall be given due consideration provided full particulars with justification there of and necessary supporting data, technical information's are furnished with quotation/offer.
- 17) Technical documents and literature : A maintenance and operation manual giving details such as operation, circuit diagram, maintenance and trouble shooting guide etc. and such details which the supplier feels necessary for satisfactory performance of the equipment.
- 18) Detail sectional drawing showing all the parts and their nomenclature.
- 19) Overall dimensional drawing, mounting details and weight of the complete unit.
- 20) Material specification and there IS equivalent.
- 21) Rating and details of protections/relays/contactors etc. provided with a unit.
- 22) Past experiences showing the details of similar type of equipment supplied to any subsidiary of CIL or Govt. agency must be submitted.
- 23) OTHER RELEVANT STANDARDS AS APPLICABLE WILL BE FOLLOWED AS UNDER :

IS13118: General requirement for circuit breakers for voltage above 1000V

IS 9046: AC contactors of voltage above 1000V up to and including 11000V

IS 9920 : Switches and switch isolators for voltage above 1000V

IS 13947 : LV switch gear and control gear

IS 10118: Code of practice for selection , installation and maintenance of switch gear and control gear

IS 4237 : General requirement for switch gear and control gear for voltage not exceeding 1000V

IS 6875	Switches and push buttons
IS 9385	High voltage fuses
IS 13703	LV fuses for voltage not exceeding 100V AC
IS 12021	Specifications of control transformers
IS 2705	CT
IS 3156	PT
IS11353	Guide for uniform system of making identification of conductors and apparatus terminals
IS2147	Degree of protection provided by enclosure for LV switch gear and control gear
IS 3043	Code of practice for earthing
IS 6005	Code of practice of phosphating iron and steel.
IS 2629	Hot dip galvanizing.
IS 1248	Electrical indicating instruments.
IS 3231	Electrical relays for power system protection
IS 1554	PVC insulated cables for working voltage up to and including 1100V.
IS 2551	Danger notice plates

TECHNICAL DATAS ARE TO BE PROVIDED :--

- 1.0 Make & Model :
- 1.1 Manufacturer's name & address:
- 1.2 Detail of Technical collaboration , if any:
- 1.3 Type : VCB and draw out/off load isolator
- 1.4 Rating(Amps):
- 1.5 Service voltage & Frequency:
 - 1.6 Enclosure:
- 1.7 Indoor type
- 1.8 Material & construction details:
 - Material Sheet
 - Thickness:
 - Whether single/two compartments :
 - Front & top cover design:
 - Skid mounted/floor stand:
 - Space between bottom of enclosure & base of skid stand:
- 1.9 Bus bar rating(Amps):
- 2.0 Material of Bus bar:
- 2.1 Current carrying capacity:
- 2.2 Isolator type & position:
- 2.3** Method of closing(manually spring assisted power)
- 2.4** Interlocking : Mechanical & Electrical

- 2.5** No. of poles
- 2.6** No. of brake in circuit per pole
- 2.7** Type if arcing contacts/ control devices
- 2.8** Type of main contacts
- 2.9** Steady hydraulic test pressure that the tanks may withstand for 1 minute without permanent distortion
- 2.10** Details of protection features provided (give main feature of each)
- 2.11** Rating of each of the contactors, CTs and PTs coils, relay etc. separately
- 2.12** Setting of range of overload trip, under voltage release etc.
- 2.13** Life(operation – hours) for each of the above
- 2.14** Minimum insulation resistance
- 2.15** Range / setting of earth leakage trip(amperes).
- 2.16** Ammeter size and scale
- 2.17** Voltmeter size and scale
- 2.18** Details of other meter and indicating lamps
- 2.19** Details of cable entry arrangement
- 2.20** Other constructional features
- 2.21** Sectional drawing showing main parts & their nomenclature
- 2.22** Circuit diagram
- 2.23** Minimum breaking capacity – MVA(enclose a copy of test certificate from CPRI)
- 2.24** Minimum breaking current symmetrical (KA)
- 2.25** Making capacity (KA) (enclose a copy of test certificate from CPRI)
- 2.26** Other test result as per IS specification
- 2.27** Overall dimension of complete unit
- 2.28** Method of mounting and dimensions
- 2.29** Weight of complete unit
- 2.30** Any special feature of the circuit breaker offered
- 2.31** Copy of orders of similar type breaker supplied to any subsidiaries of CIL or Govt. agency

FORMAT e BANK GUARANTEE
(On Non-Judicial Stamp Paper of Rs.250)

1. Messers ----- a company having its office at -----
-----hereinafter called the Seller has entered into a Contract
No.-----dt.----- (hereinafter called the said Contract) with Bharat
Coking Coal Limited (hereinafter called , the Purchaser) to supply equipment on the terms and conditions in the
said Contract.

It has been agreed that hundred percentage(100%) payment of the value of the equipment will be
made to the seller in the terms of the said Contract on the seller furnishing to the Purchaser a Bank Guarantee
for the sum of ----- equivalent to 10 % of the value of each equipment and accessories dispatched by
the seller as security for the due and faithful performance of the terms of the said contract and against any loss
or damage caused to or would be caused to or suffered by the purchaser by reason of any of the terms or
conditions contained in the said contract.

The----- Bank having its office at ----- has at the request of seller agreed to
give the guarantee herein after contained.

2. We,----- Bank Ltd. do hereby undertake to pay the amounts due and payable under this
guarantee without any demur merely on a demand from the purchaser stating that the amount claimed is due by
way of loss or damage caused to or would be caused to or suffered by the purchaser by reason of any breach by
the said seller of any of the terms or conditions contained in the said contract or by reason of the seller's failure
to perform the said contract. Any such demand made on the Bank shall be conclusive as regards the amount due
and payable by the Bank under this guarantee. We shall not withhold the payment on the ground that the seller
has disputed its liability to pay or has disputed the quantum of the amount or that any arbitration proceeding or
legal proceeding is pending between purchase and the seller regarding the claim. However , our liability under
this guarantee shall be restricted to an amount not exceeding -----.

3. We,----- Bank Ltd., further agree that the guarantee herein contained shall come into
force from the date hereof and shall remain in full force and effect during the period that would be taken for the
performance of the said contract and that it shall continue to be enforceable till all the dues of the purchase
under or by virtue of the said contract have been fully paid and its claim satisfied or purchase certified that the
terms and conditions of the said contract have been fully and properly carried out by the said seller and
accordingly discharged the guarantee .Unless a demand or claim under this guarantee is made on us in writing
on or before the -----(date to be given-----months from the date of Bank Guarantee) we shall
be discharged from all liability under this guarantee thereafter.

4. We., Bank Ltd. further agree with the purchaser ,that the purchaser , shall have the fullest liberty without our
consent and without affecting in any manner no obligations hereunder to vary any of the terms and conditions
of the said contract or to extend time of performance by the said seller(s) from time to time or to postpone for
any time or from time to time any of the powers exercisable by the purchaser , against the said seller and to
forbear or enforce any of the terms and conditions relating to the said contract and we shall not be relived from
our liability by reason or any such variation or extension being granted to the said seller or for any forbearance
act or omission on the part of the purchaser , or any indulgence by the purchaser to the said seller by any such
matter or thing whatsoever which under the law relating to sureties would be for this provision have effect of an
relieving us. The Bank further agrees that in case this guarantee is required for a longer period and it is not
extended by the bank beyond the period specified above , the bank shall pay to this purchaser the said sum of ---
----- or such lesser sum as may than be due the purchaser and as the purchaser may demand.

5. We ,----- Bank Ltd. lastly undertake not to revoke this guarantee during its currency except with the
previous consent of the purchaser , in writing.

6. The Bank has under its constitution power to give this guarantee and Mr.-----Manager , who has
signed it on behalf of the Bank has authority to do so.

7. This Bank Guarantee will not be discharged due to the change in the constitution of the Bank or the
Contractor.

Date----- Day of -----20
For ----- Bank Limited

Signature of the authorised person
for and on behalf of the Bank