

	<b>BHARAT COKING COAL LIMITED</b> ( A Subsidiary of Coal India Limited ) Office of the General Manager(MM) Materials Management Department Commercial Block L-III , Koyla Bhawan : Koyla Nagar Dhanbad : 826005(Fax No- 0326-2230183) Web site: <a href="http://www.bccl.gov.in">www.bccl.gov.in</a>
SUPPLY /PURCHASE ORDER	Under Jurisdiction Of Dhanbad Court And Jharkhand High Court Only.

Ref. No: BCCL/PUR/111073/Starter/11-12/E-TDR/57133 Dt. 08-10-2012

To  
M/s. Sait Mine Line Pvt. Ltd.,  
52, Golf Club Road,  
Kolkata – 700 033.

**REGD. POST**  
(Fax No: 033 2423 5147)

**VENDER CODE: 1/12/M/S/111**

Ref.- Tender No. BCCL/PUR/111073/Starter/11-12/E-TDR/57,  
opened on 29-08-2011.

Your Off-line documents submitted vide letter no. **SMPL/RKC/SM114/11/02**,

Dt: 20-08-2011 and subsequent Correspondence on the above subject.

Dear Sirs,

With reference to the above, we, for and on behalf of BCCL, hereby place PURCHASE ORDER on you for supply of following items as per rate , terms and conditions indicated below :

**1. SCOPE OF SUPPLY : "6.6 KV 500 HP NFLP Starter "**

SN	Description	Tender QTY (No's)	Unit Rate /No.	Extended Value
1	NFLP STARTER 6600V, 500 HP with detailed specification enclosed as Annexure-“A”	2	99300.00	198,600.00
	E.D. & Cess @12.36%			24,546.96
	CST @ 2% against Form “C”			4,462.94
	Freight @ Rs. 3500.00/No.			7,000.00
	Sub Total			2,34,609.90
	CMPDIL Inspection Charge @ 0.8% Of F.O.R. Destination value			1,876.88
	Service Tax on CMPDIL Inspection charge @12.36%			231.98
	Total Landed Value (Rs.)			2,36,718.76
	Round-Off(Rs)			2,36,719.00

**(Rs. Two Lakhs Thirty Six Thousand Seven Hundred Nineteen Only)**

**(Detailed Technical specification will be as per Annexure “A” at Page : 7-9 )**

**2. TOTAL ORDER VALUE** : The total procurement value comes out to **Rs 2,36,719.00 (Rs. Two lakhs Thirty Six Thousand Seven Hundred Nineteen Only)** on F.O.R. Destination basis inclusive of all taxes & duties and inspection charges with service tax payable to CMPDIL.

**3. PRICE**- Firm and FOR Destination.

**4. E.D. & Cess** – Payable Extra as applicable within delivery schedule at actual on documentary evidence, Present rate of E.D. & Cess is 12.36 % .

**5. CST**: Payable Extra as applicable within delivery schedule at actual on documentary evidence, Present rate of CST is @ 2 % against Form"C"(To be provided by the consignee

**6. PAYMENT TERM**:- 100% within 21 days of receipt and acceptance of the materials by the consignee or from the date of receipt of bill whichever is later by the consignee.

**7. PACKING & FORWARDING CHARGE**: Inclusive .

**8. FREIGHT** :- Maximum as indicated above

**9. TRANSIT INSURANCE CHARGES** : Inclusive

**10. MODE OF DISPATCH** : By Road on F.O.R. Destination ,Freight paid basis

*NOTE : You will ensure safe & sound delivery of stores at consignee's end .*

**11. ROAD PERMIT** : Road permit , if required , may be obtained directly from the consignee under intimation to this office .

**12. DELIVERY PERIOD** : **Delivery within 04 months of receipt of order**

However, keeping in view of our urgency, earliest delivery will be appreciated.

Delivery period shall be reckoned from 10<sup>th</sup> day of placement of order.

Any increase in the rate of taxes & duties beyond delivery period will be on your account.

<b>13. Consignee:</b>	<b>14. Paying Authority</b>
The Depot Officer, Central Stores, Ekra, B.C.C.L.	The General Manager (F)MM , Purchase Finance, Koyla Bhawan, B.C.C.L. , Dhanbad

**15. SUBMISSION OF BILL**: 100% value of bill duly stamped, signed & pre-receipted in quadruplicate , as per terms of the order should be submitted for payment to the paying authority through consignee. Bill should be submitted along with challan, Consignment note (if required), packing list if any, guarantee/warranty certificate, fitment / Test certificate if required , proof of payment of freight charges if freight is claimed, documentary evidence of Excise duty payment if claimed, Price Certificate, Copy of Inspection Note of CMPDIL (If required) and other documents as per order.

(Note – All documents to be submitted shall be duly authenticated)

(No payment will be made without submission of performance Bank Guarantee & security deposit)

THE DESIRED INFORMATION FOR RAISING VAT/CENVAT INVOICE		
	SUPPLIER	CONSIGNEE
Name & Address Of Area:		Ekra Central Store, Block – II Area, BCCL, Nawagarh, Dhanbad, Jharkhand – 828306
Tin No.:		20821500736
JST No.:		KT – 651 (R)
CST No:		KT – 254 (C)
Circle / Sub		Katras Circle Katras
Service Tax Regd. No:		AAACB7934MST 009
Central Excise Duty Regd. No:		AAACB7934MEM 007
Range (Code):		Dhanbad - Code - 02
Division (Code		Dhanbad - Code - 02
Commissionerate (Code):		Ranchi - Code - 87
PARTICULARS OF BANK ACCOUNT:		M/s Sait Mineline Pvt. Ltd. 52,Golf club Road,Kolkata-700033
Name of the Bank.		Indian Overseas Bank
Name of the Branch with complete address.		Lansdowne Market Branch, 63/1A ,Sarat Bose Road,Kolkata-700025
Party's Account Style.		M/s Sait Mineline Pvt. Ltd.
Party's nature of Account.		Cash Credit
Party's Account Number.		013502000001263

**16. GUARANTEE /WARRANTY :** The supplier shall guarantee for the satisfactory performance of the complete equipment/ stores for a period of 12 months from the date of commissioning or 18 months from the date of dispatch, whichever is earlier, against any manufacturing defects / workmanship / inferior quality. Any defect observed on this account shall be attended immediately and replace the materials within 30 days free of cost.

**17. PRICE CERTIFICATE:** You should submit a certificate along with bill as stated below:  
“The rates of the stores under this contract are the lowest at which we are selling to any other Customer / Govt. Deptt./ Subsidiaries of CIL/ Other PSUs . If the materials are sold at any lower rate than that mentioned in this contract to any other agency , the same will automatically be applied to this contract from that date"

**18. SECURITY DEPOSIT:** Waived as being NSIC Registered

**19. INSPECTION** – Pre-dispatch inspection of each consignment shall be carried out by M/s. Central Mine Planning & Design Institute Ltd(CMPDIL), Ranchi/their Regional Office as per the terms and conditions indicated hereunder:

Pre-dispatch inspection shall be carried out by M/s.CMPDIL(the above firm) as per their methodology. The third Party Inspection shall include examination of raw material, test certificate verification, continuous monitoring of quality assurance by manufacturer which will include regular and surprise visits. In brief, the scope and condition of inspection by M/s.CMPDIL will be as follows :

Checking and approval of test procedures/quality assurance plans. Verification of records and documents of your works. Verification of documents and test certificate of bought out items and cross checks.

You shall provide facilities for carrying out all necessary tests as required in the specification at your works else these will be carried out at an independent test house at your cost. Final testing and checking of materials as per specifications.

M/s.CMPDIL will have full and free access to the premises of manufacturer during the process of manufacturing and during inspection activities.

Inspection fee @ 0.80% of total F.O.R. Destination price with service Tax of 12.36%, is to be paid to M/s.CMPDIL alongwith inspection call letter payable by DD which will be reimbursed subsequently by BCCL together with consignment billing.

Minimum 7 calendar days notice shall be given by you to M/s.CMPDIL for arranging inspection within valid delivery period as per contract. The ultimate responsibility for supply of correct materials as per requirement of relevant specification lies solely with you inspite of clearance/acceptance by inspection authority i.e. M/s.CMPDIL. The manufacturer will be required to replace the material free of cost if found defective/unserviceable/not according to relevant specifications. The charges for third party inspection and the cost of materials that would be required for destructive tests, if any, shall be reimbursed by BCCL together with the consignment billing. Such cost shall be reimbursed only if it is duly certified by M/s.CMPDIL.

Please send inspection call to M/s.CMPDIL, Ranchi/ their Regional Office as indicated above Final inspection shall be arranged by the consignee after receipt of the material at our destination. The purchaser shall, at its discretion, have the right to test the ordered material in a Government Test House or in a test house nominated by the purchaser. In case of failure of the material after testing the cost of tests as well as of the material shall have to be borne by the supplier. Final inspection shall be arranged by the consignee after receipt of the material at our destination.

The purchaser shall, at its discretion, have the right to test the ordered material in a Government Test House or in a test house nominated by the purchaser. In case of failure of the material after testing the cost of tests as well as of the material shall have to be borne by the supplier.

**20. PERFORMANCE BANK GUARANTEE** – PBG on schedule/Nationalized Bank in India valid for three months beyond the expiry of Guarantee/Warranty period for 10 % value of the order (order value means FOR destination price including taxes, duties, transportation & insurance charges & other charges if any) shall have to be submitted to MM Division, BCCL, Koyla Bhawan on or before commencement of supply. PBG may be submitted either for the entire order quantity at a time or each equipment wise/lot wise.

## **21. PENALTY FOR FAILURE TO SUPPLY IN TIME**

The bidders will confirm their acceptance of the following **Liquidated Damage Clause:**

In the event of failure to deliver the equipment/stores within the stipulated date/period to effect supply in accordance with the terms and conditions and the specifications mentioned in the supply order and in the event of breach of any of the terms and conditions mentioned in the supply order, Bharat Coking Coal Ltd., shall be entitled at its option either to enforce the following:

a) To recover from the successful bidder as agreed liquidated damages, a sum of 0.5%(Half Percent) of the price of any stores which the successful tenderer has not been able to supply as aforesaid for each week or part of a week during which the delivery of such stores may be in arrears limited to **10% (Ten Percent)** and where felt necessary by BCCL it may be increased up to 15 %.

b) To cancel the supply order or a portion thereof, and if so desired to purchase the stores at the risk and expenses of the defaulting supplier and also/or

- c) To purchase elsewhere after notice to the successful tenderer on the account and at the risk of the defaulting supplier, the equipment/stores not supplied or others of similar description without canceling the supply order in respect of the consignment not yet due for supply/or
- d) To extend the period of delivery with or without liquidated damages as may be considered fit and proper. The liquidated damages if imposed, shall not be more than the agreed liquidated damages referred to in CLAUSE 14 (a) above except in case of force majeure condition.
- e) Whenever under this contract any sum of money is recoverable from and payable by the supplier, Bharat Coking Coal Ltd., shall be entitled to recover such sum by appropriating in part or in whole by deducting any sum or which at any time thereafter may become due to the successful tenderer in this or any other contract, should this sum be not sufficient to recover the full amount recoverable. The successful tenderer shall pay to Bharat Coking Coal Ltd., the balance amount on demand of the remaining balance. The supplier shall not be entitled for any gain on any such purchase.
- f) To forfeit the security deposit fully or in part.

**22. PRICE FALL CLAUSE :**

- i) The price charged for the Stores / Equipment supplied against the order, if placed, shall in no event exceed the lowest price at which the bidder shall sell or offer to sell the Stores / Equipment of identical description to its any other customer during the pendency of the Contract / Supply Order. If the successful tenderer at any time during the pendency of the Contract / Supply Order sells or offers to sell such stores to any customer, at a price lower than the price stipulated in the Contract / Supply Order placed by BCCL, the successful tenderer shall forthwith notify to BCCL such reduction in sale price of stores / equipment supplied after such reduction coming into force shall stand correspondingly reduced.

All other terms & conditions along with Technical Specifications and Scope of supply will strictly be as per our NIT and company's norms.

**ALL DISPUTES ARE SUBJECT TO DHANBAD COURT AND JHARKHAND HIGH COURT JURISDICTION ONLY.**

This contract is concluded with the issuance of this order. Two copies of the order is being sent to you. You are advised to acknowledge the receipt and acceptance of the order by returning one copy duly signed and stamped to this office positively within 15 days, failing which this order shall be deemed to have been accepted by you for execution.

**Encl.: Annexure "A"**

**INDENT & BUDGET CERTIFICATION REFERENCE**

Indent no. and Date	BC &FC No. & dt.
BCCL/CGM(E&M)/F-Central Indent(Elect)/2010-11/38 dated: 30-03-2011 IR No. 111073 (11-12) ,Dated: 22-06-2011	BCCL/C&B/Cap/12-13/P&M/HQ/121/99/249 e-BC Dt: 27-09-2012 For Rs. 1,57,73,517.00 e-FC no 97 Dt: 29-09-2012 (HQ P&P) For Rs.1,57,73,517.00

**Copy to:**

- 1. Depot Officer, Ekra Central Stores.
- 2. G.M.(F)(MM), MM DIV, Koyla Bhawan.
- 3. CGM(E&M), Koyla Bhawan.
- 4. C.M.(MM)(Tech Cell), MM Div, Koyla Bhawan.
- 5. CGM(E&M), CMPDIL, Gondwana Place, Kanke Road, Ranchi
- 6. CGM(MM)/GM(MM), CCL / WCL/ SECL / MCL / ECL.
- 7. Master File/Office Copy
- 8. Special Cell, CMPDIL, Gondwana Place, Kanke Road, Ranchi
- 9. Sri D. Bandopadhyay, IAS (Retd.),G.D.- 89, Sector-III, Salt lake , Kolkata-700016

Yours faithfully,  
For & on behalf of Bharat Coking Coal Ltd.

(Niraj Kumar)  
Manager(Excvn)MM

(AK CHOUDHARY)  
CM (MM)

**ANNEXURE-“A”****SPECIFICATION OF 6.6 KV STARTER****1.0 SCOPE**

This specification covers the requirement for three phase direct on line starter for 6.6 KV motors.

The standard shall comply with the requirement of IS 12661 for HT motors except where modified or extended by the provision of this specification and with the relevant parts of standard mentioned in clause 2.0

Any material and component not specifically stated in this specification but necessary for trouble free operation of the equipment and the accessories specified herein shall be deemed to be included .

**2.0 OTHER RELEVANT STANDARDS**

The other relevant standards applicable as under

IS 5142 Continuous variable voltage auto transformers

IS 11171 Dry type transformers

IS 5553 Current limiting reactor

IS 13118 General requirement for circuit breakers for voltage exceeding 1000V

IS 13947 (Part-3) Fuse switch units not exceeding 1000V A.C.

IS 9920 HT Isolators and switches

IS 13947 (Part-5) Rotary switch not exceeding 1000V A.C.

IS 10624 High Voltage fuse link for motor circuit application

IS 9385 (Part -1) High voltage fuses ( current limiting fuses)

IS 9385 (Part – 3) Application guide for high voltage fuses

IS 9385 (Part – 5) High voltage fuses . Type & dimensions of fuse link for current limiting fuses

IS 13703(Part1-4) LV Fuses not exceeding 1000V A.C.

IS 12021 Specification for control transformers for voltages not exceeding 1000 V A.C.

IS 13974 AC Contactors not exceeding 1000V A.C.

IS 9046 AC Contactors above 1000V upto and including 11000V A.C.

IEC 470 HV AC Contactors(Vacuum)

IS 2705 Current Transformer

IS 6949 Core balance transformer

IS 3156 Voltage transformer

IS 1766 Time switch

IS 8588 Thermostatic bimetals

IS 3842 Electric relays for AC system

IS 722 AC Electricity meters

IS 1248 Indicating instruments

IS 1901 Indicating lamps

IS 2419 Dimensions of measuring instruments

IS 2147 Degree of protection provided by industrial enclosure

IS 2148 FLP Enclosure for electrical apparatus

IS 1554 PVC Insulated heavy duty cables for working voltage not exceeding 11000V

IS 2274 Electrical wiring of installations

IS 3043 Code of practice for earthing

IS 732 Code of practice for electrical wiring

IS 3072 Code of practice for installation and maintenance of switch gears

The equipment covered under this specification shall comply with all the latest applicable statutory rules , regulations , acts and safety codes which may be in force during the period of execution and which are related with design construction and operation of equipment in the locality where equipment is to be installed .

### **3.0 Service condition :**

- a) Location : Heavily polluted atmosphere with coal dust for NFLP  
and Degree three gassy mine for FLP

### **4.0 Design**

#### **4.1 Electrical :**

- a) All Starter shall be designed for over load, short circuit , and earth leakage protection
- b) Over load and short circuit protection by solid state relays . Range of current adjustment 50% to 150 % of full load current and Instantaneous setting 200 to 600 % .
- c) Earth leakage relay –Fail safe sensitive earth leakage based on solidly grounded neutral system. Earth leakage relay have setting from 0A to 5A with a time lag with test and reset from outside. Earth leakage relay shall be of high quality and subjected to relevant test as per the Indian standard or IEC to ensure satisfactory performance. The report of standard test house for the same should be submitted
- d) All Starter shall be designed to prevent sudden starting after the restoration of power supply.
- e) All Starter shall be designed for protection against single phasing (current sensing)

#### **4.2 Mechanical :**

- a) All starter shall be designed to withstand the thermal and electromagnetic stresses due to over load and short circuit faults .
- b) All Starter shall be designed for easy accessibility to components for inspection and maintenance .
- c) All Starter shall be designed for safety interlock to ensure opening of the door only when the isolator is off.

### **5.0 Construction :**

#### **5.1 Electrical :**

- a) All power contactors of starters shall be AC – 3 in accordance with relevant codes. Vacuum contactor will have to provide for 6.6 KV starter . The make of contactor will be L & T / Semen's / ABB / Tele mechanics ,or any reputed make. Rating of contactor should be . Thrice the full load current.
- b) HRC fuse on starters shall be current limiting type. HRC fuse shall be cartridge type mounted on compatible fuse base
- c) Starter shall have ON/OFF/RESET push buttons .
- d) Starter shall have glow lamp for each phase .
- e) Starter shall have ammeter with selector switch .
- f) Starters shall have CT for protection & metering and have CBT for Earth leakage protection.
- g) 6.6 KV Starters shall have Voltage transformer for measurement.
- h) Starters shall have timers. The setting shall be between 2 to 60seconds..
- i) The off load interlocked reversing isolator of capacity 300% of full load current shall be provided.



5.2 Mechanical :

- a) NFLP shall have Industrial enclosure  
All NFLP starters shall have IP 44 and IP 54 degree of protection in indoor & outdoor location respectively in accordance with relevant code .3
- b)All NFLP starters shall have enclosure made of MS Sheet 1.6 mm thick
- c)Starters shall be free standing floor mounted skid type.
- d)Starter shall have two separate earthing terminals on two diagonally opposite corner for earthing of the enclosure.
- e)Cable terminal for NFLP Starter shall have IP 54 degree of protection in all location
- f)Cable terminal box shall have FLP enclosure for incoming outgoing and through going cable sealing/ terminating box, suitable for mining type PVC /PILC, DWA.

6.0Technical Parameters :

- 1. Reference standard : IS 13947(Part 4) / IS 12661
- 2. Reference standard for enclosure : IS 2148 /IS 2147
- 3. Type of starter : Star delta
- 4. Rated voltage of starter : 6.6KV
- 5. Rated power

Sl. no.	Voltage	H.P.	Quantity Required (no's )	Busbar Rating	Contactor Rating
1.	6600 V	500	2	400A	Thrice the full load current

- 6 Contactor category : AC – 3
- 7 Contactor make : Semen’s / ABB / L & T / Tele mechanics ,or any reputed make
- 8 Type of contactor : Vacuum Of rating thrice the full load.
- 9. Ammeter & Voltmeter : Required
- 10.Auxiliary contact for
  - Earth leakage protection : Required
  - No volt protection : Required
- 10. Mounting : Floor mounting skid type
- 11. Clearance between phases : 70 mm for HT
- 12. Clearance between phase to phase : 60 mm for HT .
- 13.Successful bidder has to submit self attested copy of all types of routine tests as per relevant Standard.
- 14. Following documents shall have to be submitted at the time of supply :-
  - a) Operation and maintenance manual.
  - b) Spare part list with circuit diagram.